



Andrew J. Spano
County Executive

Department of Health
Joshua Lipsman, M.D., M.P.H.
Commissioner

May 12, 2005

Arshad Jalil, P.E., Vice President
Professional Consulting, LLC
Octagon 10 Office Center
1719 Route 10, Suite 225
Parsippany, NJ 07054

RE: Reduced Monitoring
Lead/Copper
Tarrytown Public Water Supply
PWS ID: NY5903461
Village of Tarrytown

Dear Mr. Jalil:

Receipt of your letter dated May 11, 2005 requesting a reduction in the monitoring frequency of lead and copper for the above referenced public water supply is hereby acknowledged.

Based upon the results of lead and copper monitoring during 2001 through 2004, this Department hereby grants your request to reduce the frequency of first draw lead and copper tap monitoring to once every three (3) years at the reduced number of sampling sites in accordance with Part 5, Subpart 5-1, Section 5-1.42 of the New York State Sanitary Code.

If there are any questions, please contact Delroy Taylor, P.E. at (914) 813-5150.

I remain,

Michael J. Sakala, P.E.
Assistant Commissioner
Bureau of Environmental Quality

MJS:DT:jm

cc: Michael McGarvey, P.E. - Tarrytown
Scott Weaver, Gen'l. Foreman - Tarrytown
Darrell Lindsay, Designated Op. - Tarrytown
Jack Dunn, P.E. - NYSDOH
George Philip, P.E. - NYSDOH
Paul Kutzy, P.E. - WCDOH
✓ Delroy Taylor, P.E. - WCDOH
File